



Ted Wynne Engineering/Contractor, Inc.

417 WELSHWOOD DRIVE • SUITE 114 • NASHVILLE, TN 37211
PHONE: 615-331-7660 • FAX: 615-333-0764

August 4, 2000

Mr. Bill Stalker
Tennessee Valley Authority
P.O. Box 292409, Bldg 1, Suite 300
565 Marriott Drive
Nashville, Tennessee 37229-2409

Re: Free Will Baptist College
Joelton, Tennessee

This office performed a thermal conductivity test on one (1) 300 feet deep, 6 inch diameter vertical bore, backfilled with drilled tailings, July 26, 2000. The following data was derived from test data:

Thermal Conductivity	2.1 BTU/HR-F
Ground Temperature	59.6 F

We feel that based on our observation of the terrain, the above is representative of the area where a field of Vertical Heat Exchangers will be located for this project.

The driller's log is enclosed herewith. According to the Driller's Log submitted to our office the bore hole penetrated more than one water source, thus our office recommends that any future holes drilled should be Grouted to prevent transfer of water from one elevation to another.

Please let us know if any additional information is needed.

Sincerely,

TED WYNNE ENGINEERING CONTRACTORS, INC.


Ted Wynne, P.E.

jh



